

Data Centre Site Certification

This certification is awarded to

TIA942 rating

Telecommunications: Rating 3

Electrical: Rating 3 2N

Architectural Rating 3

Mechanical N+1

OMAN DATA PARK

Zone 2, 7th Floor. KOM4

Knowledge Oasis Muscat

PO Box 789, PC 112 Ruwi

Sultanate of Oman

The site audited by us on 4-7-17 complies with the Rating 3 requirements of ANSI-TIA942:2014 for Telecommunications, Electrical and Architectural requirements and N+1 for the mechanical (cooling) systems. This certificate should be read in conjunction with Capitoline report DDA01098 12/7/17. Capitoline Ltd makes no warranty of the suitability of this site beyond those defined in our report.

Authorised By



B Elliott CEng MIET MBA, BSc (Hons), DCE ATD RCDD

Issue date: 25th August 2017

Valid till: 24th August 2019

